



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038845

Project : PO#126993

11-August-2022

PVNC Catholic DSB (Reg243 - St Thomas Aquinas SS)

Attn : Donna Sorrell

Date Rec. : 08 August 2022

LR Report: CA17705-AUG22

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	11-Aug-22
2: Analysis Start Time		---	08:00
3: Analysis Completed Date		---	11-Aug-22
4: Analysis Completed Time		---	14:04
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 254-FT-001	02-Aug-22 06:44	22.0	2.08
8: TAP Flushed - 254-FT-001	02-Aug-22 07:21	22.0	0.84
9: TAP Standing - 254-FT-003	05-Aug-22 06:30	22.0	1.06
10: TAP Flushed - 254-FT-003	05-Aug-22 07:05	22.0	1.25
11: TAP Standing - 254-FT-002	03-Aug-22 06:43	22.0	0.39
12: TAP Flushed - 254-FT-002	03-Aug-22 07:21	22.0	0.28
13: TAP Standing - 254-FT-004	04-Aug-22 06:09	22.0	0.58
14: TAP Flushed - 254-FT-004	04-Aug-22 06:44	22.0	0.27
15: TAP Standing - 254-FT-005	05-Aug-22 06:12	22.0	0.22
16: TAP Flushed - 254-FT-005	05-Aug-22 06:48	22.0	0.19

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety