



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038845

Project : PO#126993

19-August-2021

PVNC Catholic DSB (Reg243 - St Thomas Aquinas SS)

Attn : Donna Sorrell

Date Rec. : 12 August 2021

LR Report: CA18436-AUG21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	18-Aug-21
2: Analysis Start Time		---	06:30
3: Analysis Completed Date		---	18-Aug-21
4: Analysis Completed Time		---	12:02
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Fountain By Rm 111	09-Aug-21 06:04	24.0	3.32
8: TAP Flushed - Fountain By Rm 111	09-Aug-21 06:40	24.0	0.49
9: TAP Standing - Fountain Tech Building	09-Aug-21 06:15	24.0	0.68
10: TAP Flushed - Fountain Tech Building	09-Aug-21 06:52	24.0	1.29
11: TAP Standing - Fountain by Gym	10-Aug-21 05:59	24.0	2.40
12: TAP Flushed - Fountain by Gym	10-Aug-21 06:35	24.0	0.47
13: TAP Standing - Fountain by 228	11-Aug-21 06:00	24.0	33.7 MAC
14: TAP Flushed - Fountain by 228	11-Aug-21 06:36	24.0	0.82
15: TAP Standing - Fountain by 226	12-Aug-21 05:56	24.0	1.24
16: TAP Flushed - Fountain by 226	12-Aug-21 06:32	24.0	0.27

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

MAC - (ADVERSE) Above Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038845

Project : PO#126993

LR Report : CA18436-AUG21

Carrie Greenlaw
Carrie Greenlaw
Project Specialist,
Environment, Health & Safety