



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500107381

Project : PO#126993

04-August-2020

PVNC Catholic DSB (Reg243 - St Joseph's ES-Douro)

Attn : Donna Sorrell

Date Rec. : 30 July 2020

LR Report: CA17402-JUL20

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	04-Aug-20
2: Analysis Start Time		---	10:11
3: Analysis Completed Date		---	04-Aug-20
4: Analysis Completed Time		---	11:49
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - SK-003	29-Jul-20 05:18	20.0	19.2 MAC
8: TAP Flushed - SK-003	29-Jul-20 05:49	20.0	8.94
9: TAP Standing - SK-005	29-Jul-20 05:24	20.0	2.31
10: TAP Flushed - SK-005	29-Jul-20 05:55	20.0	1.26
11: TAP Standing - SK-001	29-Jul-20 05:21	20.0	8.16
12: TAP Flushed - SK-001	29-Jul-20 05:52	20.0	1.79
13: TAP Standing - SK-002	29-Jul-20 05:33	20.0	12.6 MAC
14: TAP Flushed - SK-002	29-Jul-20 05:57	20.0	1.62
15: TAP Standing - FT-001	29-Jul-20 05:29	20.0	9.20 RVNS
16: TAP Flushed - FT-001	29-Jul-20 05:59	20.0	2.59 RVNS
17: TAP Standing - FT-002	29-Jul-20 05:26	20.0	3.21 RVNS
18: TAP Flushed - FT-002	29-Jul-20 06:01	20.0	6.08 RVNS

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety