



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038806

Project : PO#126993

28-July-2020

PVNC Catholic DSB (Reg243 - St Paul's ES-Lakefield)

Attn : Donna Sorrell

Date Rec. : 22 July 2020

LR Report: CA16954-JUL20

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	28-Jul-20
2: Analysis Start Time		---	10:10
3: Analysis Completed Date		--	28-Jul-20
4: Analysis Completed Time		--	12:24
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 105-BF-001	22-Jul-20 05:45	23.0	0.82 RVNS
8: TAP Flushed - 105-BF-001	22-Jul-20 06:15	23.0	0.40 RVNS

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit
RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety