



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500035907

Project : PO#126993

10-August-2020

PVNC Catholic DSB (Reg243 - St Alphonsus ES)

Attn : Donna Sorrell

Date Rec. : 04 August 2020

LR Report: CA17510-AUG20

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	10-Aug-20
2: Analysis Start Time		---	08:40
3: Analysis Completed Date		--	10-Aug-20
4: Analysis Completed Time		--	11:28
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 108-SK-003	29-Jul-20 06:00	22.0	7.41
8: TAP Flushed - 108-SK-003	29-Jul-20 06:35	22.0	7.93
9: TAP Standing - 108-FT-002	02-Aug-20 10:15	22.0	10.2 MAC RVMS
10: TAP Flushed - 108-FT-002	02-Aug-20 10:50	22.0	6.52 RVNS
11: TAP Standing - 108-SK-002	30-Jul-20 06:00	22.0	11.2 MAC RVNS
12: TAP Flushed - 108-SK-002	30-Jul-20 06:35	22.0	18.3 MAC RVNS
13: TAP Standing - 108-FT-003	31-Jul-20 06:00	22.0	10.3 MAC RVNS
14: TAP Flushed - 108-FT-003	31-Jul-20 06:35	22.0	6.17 RVNS

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety