



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500002835

Project : PO#126993

05-August-2020

PVNC Catholic DSB (Reg243 - St Anne's ES)

Attn : Donna Sorrell

Date Rec. : 30 July 2020

LR Report: CA15805-JUL20

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	05-Aug-20
2: Analysis Start Time		---	09:47
3: Analysis Completed Date		---	05-Aug-20
4: Analysis Completed Time		---	11:06
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 109-SK-002	29-Jul-20 07:00	25.0	1.09 RVNS
8: TAP Flushed - 109-SK-002	29-Jul-20 07:35	25.0	0.66
9: TAP Standing - 109-FT-002	29-Jul-20 07:00	25.0	0.98 RVNS
10: TAP Flushed - 109-FT-002	29-Jul-20 07:35	25.0	1.10 RVNS

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety