



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038611

Project : PO#126993

01-September-2020

PVNC Catholic DSB (Reg243 - St Paul's ES-Peterborough)

Attn : Donna Sorrell

Date Rec. : 26 August 2020

LR Report: CA17231-AUG20

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	31-Aug-20
2: Analysis Start Time		---	11:12
3: Analysis Completed Date		---	01-Sep-20
4: Analysis Completed Time		---	09:50
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 112-FT-004	21-Aug-20 07:10	21.0	7.03
8: TAP Flushed - 112-FT-004	21-Aug-20 07:50	21.0	4.16
9: TAP Standing - 112-FT-005	21-Aug-20 07:15	21.0	5.17
10: TAP Flushed - 112-FT-005	21-Aug-20 07:55	21.0	2.36
11: TAP Standing - 112-SK-001	21-Aug-20 08:00	21.0	1.57
12: TAP Flushed - 112-SK-001	21-Aug-20 08:35	21.0	0.93
13: TAP Standing - 112-FT-001	24-Aug-20 08:05	21.0	7.32
14: TAP Flushed - 112-FT-001	24-Aug-20 08:40	21.0	5.16
15: TAP Standing - 112-FT-003	24-Aug-20 06:50	21.0	2.08
16: TAP Flushed - 112-FT-003	24-Aug-20 07:25	21.0	2.00

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety