



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500149579

Project : PO#126993

16-September-2020

PVNC Catholic DSB (Reg243 - St Luke's ES)

Attn : Donna Sorrell

Date Rec. : 11 September 2020

LR Report: CA18403-SEP20

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	16-Sep-20
2: Analysis Start Time		---	09:20
3: Analysis Completed Date		--	16-Sep-20
4: Analysis Completed Time		--	11:30
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 130-FT-002	09-Sep-20 07:10	21.0	4.93 RVNS
8: TAP Flushed - 130-FT-002	09-Sep-20 07:45	21.0	1.38
9: TAP Standing - 130-SK-001	09-Sep-20 07:10	21.0	230 MAC RVNS
10: TAP Flushed - 130-SK-001	09-Sep-20 07:45	21.0	0.81 RVNS

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety