



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500002913

Project : PO#126993

30-July-2020

PVNC Catholic DSB (Reg243 - Good Shepherd ES)

Attn : Donna Sorrell

Date Rec. : 27 July 2020

LR Report: CA14902-JUL20

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Lead ug/L |
|------------------------------|--------------------|-----------------------------|-----------|
| 1: Analysis Start Date | | --- | 30-Jul-20 |
| 2: Analysis Start Time | | --- | 09:59 |
| 3: Analysis Completed Date | | --- | 30-Jul-20 |
| 4: Analysis Completed Time | | --- | 11:42 |
| 5: MAC | | --- | 10 |
| 6: MDL | | --- | 0.01 |
| 7: TAP Standing - 135-FT-001 | 22-Jul-20 06:30 | 25.0 | 0.24 RVNS |
| 8: TAP Flushed - 135-FT-001 | 22-Jul-20 07:05 | 25.0 | 0.34 RVNS |

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

Method Descriptions

| Parameter | Description | SGS Method Code |
|-----------|-------------------------------|---------------------------|
| Lead | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 |

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety