



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038689

Project : PO#126993

10-September-2020

PVNC Catholic DSB (Reg243 - Holy Family ES)

Attn : Donna Sorrell

Date Rec. : 04 September 2020

LR Report: CA14089-SEP20

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	10-Sep-20
2: Analysis Start Time		---	09:09
3: Analysis Completed Date		--	10-Sep-20
4: Analysis Completed Time		--	11:10
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 137-FT-001	02-Sep-20 05:40	22.0	0.36
8: TAP Flushed - 137-FT-001	02-Sep-20 07:15	22.0	0.11

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety