



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038715

Project : PO#126993

24-August-2020

PVNC Catholic DSB (Reg243 - Holy Trinity)

Attn : Donna Sorrell

Date Rec. : 19 August 2020

LR Report: CA16938-AUG20

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	24-Aug-20
2: Analysis Start Time		---	09:31
3: Analysis Completed Date		--	24-Aug-20
4: Analysis Completed Time		--	10:58
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 255-BF-001	18-Aug-20 06:00	21.0	0.09
8: TAP Flushed - 255-BF-001	18-Aug-20 06:10	21.0	0.09 RVNS

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit
RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety