



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038793

**Project :** PO#126993

23-July-2020

**PVNC Catholic DSB (Reg243 - St Mary's SS)**

Attn : Donna Sorrell

**Date Rec. :** 20 July 2020

**LR Report:** CA14602-JUL20

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	23-Jul-20
2: Analysis Start Time		---	09:12
3: Analysis Completed Date		---	23-Jul-20
4: Analysis Completed Time		---	09:19
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 256-BF-001	17-Jul-20 06:00	16.0	0.28
8: TAP Flushed - 256-BF-001	17-Jul-20 06:35	16.0	0.10

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety