



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038728

Project : PO#126993

21-July-2020

PVNC Catholic DSB (Reg243 - St Stephen's SS)

Attn : Donna Sorrell

Date Rec. : 16 July 2020

LR Report: CA18200-JUL20

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	21-Jul-20
2: Analysis Start Time		---	10:22
3: Analysis Completed Date		---	21-Jul-20
4: Analysis Completed Time		---	11:19
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 257-FT-001	14-Jul-20 06:02	15.0	0.42
8: TAP Flushed - 257-FT-001	14-Jul-20 06:37	15.0	1.53

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety