



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 260014300

**Project :** PO#126993

19-October-2020

**PVNC Catholic DSB (St Lukes-Downeyville)**

Attn : Donna Sorrell

**Date Rec. :** 14 October 2020

**LR Report:** CA16759-OCT20

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912  
Fax:School Fax: 705-799-0583

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date		---	14-Oct-20	14-Oct-20
2: Analysis Start Time		---	18:08	18:08
3: Analysis Completed Date		---	16-Oct-20	16-Oct-20
4: Analysis Completed Time		---	16:30	16:30
5: MAC		---	0	0
6: DW DW-Kindergarten Room	14-Oct-20 13:55	6.0	0	0
7: RW RW-Utility Room	14-Oct-20 14:00	6.0	0	0

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by membrane filtration using DC medi	ME-CA-[ENV]MIC-LAK-AN-001



Carrie Greenlaw  
Project Specialist,  
Environment, Health & Safety