



Part III Form 2
Section 11. ANNUAL REPORT.

Table with 2 columns: Label (Drinking-Water System Number, Name, Owner, Category, Period) and Value (260014261, Monsignor Leo Cleary, Peterborough Victoria Northumberland Clarington Catholic District School Board, Small Non Municipal Non Residential - Designated, April 1, 2020 to March 31, 2021)

Form with two columns. Left column: 'Complete if your Category is Large Municipal Residential or Small Municipal Residential'. Right column: 'Complete for all other Categories.' Includes questions about serving more than 10,000 people, public availability of reports, and number of facilities/authorities served.

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Table with 2 columns: Drinking Water System Name, Drinking Water System Number. Row 1: None, (empty)

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [] No [] N/A [x]



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

Source
 - One (1) drilled well

Treatment
 - Water softener
 - Two (2) 5µm cartridge filters
 - Primary disinfection provided by two (2) UV disinfection units with shut-off solenoids
 - Secondary disinfection provided by chlorination
 - water softener

List all water treatment chemicals used over this reporting period

Sodium hypochlorite for secondary disinfection
 Sodium chloride for water softener regeneration

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

- Replaced UV lamps and Pressure gauge
 - General Maintenance

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	12	0 - 0	0 - 0	-	-
Treated	4	-	-	-	-
Distribution	12	0 - 0	0 - 0	-	-

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure
Turbidity	N/A		
Chlorine	238	0.00 – 0.55	mg/L
Fluoride (If the DWS provides fluoridation)	N/A		

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	August 23, 2016	0.12	µg/L	No
Arsenic	August 23, 2016	0.2#<MDL	µg/L	No
Barium	August 23, 2016	73	µg/L	No
Boron	August 23, 2016	90	µg/L	No
Cadmium	August 23, 2016	0.003#<MDL	µg/L	No
Chromium	August 23, 2016	0.43	µg/L	No
*Lead (standing) 127-SK-002	June 20, 2019	6.97##RVNS	µg/L	No (1/2 exceed)
*Lead (flushed) 127-SK-002	June 20, 2019	5.50##RVNS	µg/L	No (1/2 exceed)
Mercury	August 23, 2016	0.01#<MDL	µg/L	No
Selenium	August 23, 2016	0.17	µg/L	No
Sodium	August 23, 2016	134##MAC	mg/L	Yes

Uranium	August 23, 2016	0.568	µg/L	No
Fluoride	August 23, 2016	0.06#<MDL	mg/L	No
Nitrite	May 12, 2020	0.046	as N mg/L	No
	August 21, 2020	0.006	as N mg/L	No
	November 18, 2020	0.003#<MDL	as N mg/L	No
	February 19, 2021	0.005	as N mg/L	No
Nitrate	May 12, 2020	1.42	as N mg/L	No
	August 21, 2020	1.06	as N mg/L	No
	November 18, 2020	0.814	as N mg/L	No
	February 19, 2021	0.82	as N mg/L	No

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing				
Distribution				

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
1,1-Dichloroethylene-DW	August 23, 2016	0.33#<MDL	µg/L	No
1,2-Dichlorobenzene-DW	August 23, 2016	0.41#<MDL	µg/L	No
1,2-Dichloroethane-DW	August 23, 2016	0.35#<MDL	µg/L	No
1,4-Dichlorobenzene-DW	August 23, 2016	0.36#<MDL	µg/L	No
2,4-D-DW	August 23, 2016	0.19#<MDL	µg/L	No
2,4-Dichlorophenol-DW	August 23, 2016	0.15#<MDL	µg/L	No
Alachlor-DW	August 23, 2016	0.02#<MDL	µg/L	No
Atrazine+metabs-DW	August 23, 2016	0.01#<MDL	µg/L	
Atrazine-DW	August 23, 2016	0.01#<MDL	µg/L	No
Azinphos-methyl-DW	August 23, 2016	0.05#<MDL	µg/L	No
Benzene-DW	August 23, 2016	0.32#<MDL	µg/L	No
Benzo(a)pyrene-DW	August 23, 2016	0.004#<MDL	µg/L	No
Bromoxynil-DW	August 23, 2016	0.33#<MDL	µg/L	No
Carbaryl-DW	August 23, 2016	0.05#<MDL	µg/L	No
Carbofuran-DW	August 23, 2016	0.01#<MDL	µg/L	No
Carbon tetrachloride-DW	August 23, 2016	0.16#<MDL	µg/L	No
Chlorpyrifos-DW	August 23, 2016	0.02#<MDL	µg/L	No



Desethyl atrazine-DW	August 23, 2016	0.01#<MDL	µg/L	No
Diazinon-DW	August 23, 2016	0.02#<MDL	µg/L	No
Dicamba-DW	August 23, 2016	0.20#<MDL	µg/L	No
Dichloromethane-DW	August 23, 2016	0.35#<MDL	µg/L	No
Diclofop-methyl-DW	August 23, 2016	0.40#<MDL	µg/L	No
Dimethoate-DW	August 23, 2016	0.03#<MDL	µg/L	No
Diquat-DW	August 23, 2016	1#<MDL	µg/L	No
Diuron-DW	August 23, 2016	0.03#<MDL	µg/L	No
Glyphosate-DW	August 23, 2016	1#<MDL	µg/L	No
Malathion-DW	August 23, 2016	0.02#<MDL	µg/L	No
MCPA-DW	August 23, 2016	0.00012#<MDL	mg/L	No
Metolachlor-DW	August 23, 2016	0.01#<MDL	µg/L	No
Metribuzin-DW	August 23, 2016	0.02#<MDL	µg/L	No
Monochlorobenzene-DW	August 23, 2016	0.3#<MDL	µg/L	No
Paraquat-DW	August 23, 2016	1#<MDL	µg/L	No
PCB-DW	August 23, 2016	0.04#<MDL	µg/L	No
Pentachlorophenol-DW	August 23, 2016	0.15#<MDL	µg/L	No
Phorate-DW	August 23, 2016	0.01#<MDL	µg/L	No
Picloram-DW	August 23, 2016	1#<MDL	µg/L	No
Prometryne-DW	August 23, 2016	0.03#<MDL	µg/L	No
Simazine-DW	August 23, 2016	0.01#<MDL	µg/L	No
Terbufos-DW	August 23, 2016	0.01#<MDL	µg/L	No
Tetrachloroethylene-DW	August 23, 2016	0.35#<MDL	µg/L	No
Tetrachlorophenol-DW	August 23, 2016	0.20#<MDL	µg/L	No
Triallate-DW	August 23, 2016	0.01#<MDL	µg/L	No
Trichloroethylene-DW	August 23, 2016	0.44#<MDL	µg/L	No
Trichlorophenol-DW	August 23, 2016	0.25#<MDL	µg/L	No
Trifluralin-DW	August 23, 2016	0.02#<MDL	µg/L	No
Vinyl Chloride-DW	August 23, 2016	0.17#<MDL	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample