

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260096902-NR**Project :** PO#126993

17-April-2023

PVNC Catholic DSB (St Josephs-Douro - Cistern System)**Attn :** Mwenu Amukun**Date Rec. :** 14 April 2023**LR Report:** CA16582-APR23

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521
Fax: School Fax: 705-652-8247

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date		---	14-Apr-23	14-Apr-23
2: Analysis Start Time		---	14:40	14:40
3: Analysis Completed Date		---	17-Apr-23	17-Apr-23
4: Analysis Completed Time		---	11:56	11:56
5: MAC		---	0	0
6: NR NR-Well Water	14-Apr-23 08:25	6.0	3	0

MAC - Maximum Acceptable Concentration

NR - Not regulated / reportable under applicable Provincial drinking water regulations as per client.

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety