

SGS Canada Inc. P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO Phone: 705-652-2000 FAX: 705-652-6365

PVNC Catholic DSB (St Martins-Ennismore)

Attn : Mwenu Amukun

1355 Lansdowne Street West Peterborough, ON K9J 7M3, Canada

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521 Fax:School Fax: 705-292-1915

CERTIFICATE OF ANALYSIS **Final Report**

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date				14-Apr-23	14-Apr-23
2: Analysis Start Time				14:40	14:40
3: Analysis Completed Date				17-Apr-23	17-Apr-23
4: Analysis Completed Time				11:57	11:57
5: MAC				0	0
6: DW DW-Staff Room	14-Apr-23 13:10	6.0	2.10	0	0
7: RW RW-Utility Room	14-Apr-23 13:20	6.0		2	0

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code	
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001	
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001	

letur)

Kimberley Didsbury Project Specialist, Environment, Health & Safety

0003301336

DhLine LIMS

Page 1 of 1 Results relate only to the sample tested. Data reported represents the sample submitted to SGS. Reproduction of this analytical report in full or in part is prohibited without prior written approval. Please refer to SGS General Conditions of Services located at https://www.sgs.ca/en/terms-and-conditions (Printed copies are available upon request.) Test method information available upon request. "Temperature Upon Receipt" is representative of the whole shipment and may not reflect the temperature of individual samples. SGS Canada Inc. Environment-Health & Safety statement of conformity decision rule does not consider uncertainty when analytical results are compared to a specified standard or regulation.

Works #: 260014313 Project : PO#126993

17-April-2023

Date Rec.: 14 April 2023 LR Report: CA16587-APR23

Copy: #1