

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 260096902**Project :** PO#126993

15-September-2023

**PVNC Catholic DSB (St Josephs-Douro - Cistern System)****Attn :** Mwenu Amukun

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Date Rec. :** 14 September 2023**LR Report:** CA16536-SEP23**Copy:** #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521

Fax: School Fax: 705-652-8247

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date		---	---	14-Sep-23	14-Sep-23
2: Analysis Start Time		---	---	16:05	16:05
3: Analysis Completed Date		---	---	15-Sep-23	15-Sep-23
4: Analysis Completed Time		---	---	15:39	15:39
5: MAC		---	---	0	0
6: DW DW - Staff Room	14-Sep-23 08:30	9.0	1.29	0	0
7: TW TW - Cistern Water	14-Sep-23 08:20	9.0	1.42	0	0

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury  
Project Specialist,  
Environment, Health & Safety