

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260014313**Project :** PO#126993

17-July-2023

PVNC Catholic DSB (St Martins-Ennismore)**Attn :** Mwenu Amukun

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Date Rec. : 12 July 2023**LR Report:** CA18383-JUL23**Copy:** #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521
Fax: School Fax: 705-292-1915

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date		---	---	13-Jul-23	13-Jul-23
2: Analysis Start Time		---	---	11:43	11:43
3: Analysis Completed Date		---	---	17-Jul-23	17-Jul-23
4: Analysis Completed Time		---	---	08:49	08:49
5: MAC		---	---	0	0
6: DW DW-Staff Room	12-Jul-23 14:10	11.0	0.23	0	0
7: RW RW-Utility Room	12-Jul-23 14:15	11.0	---	0	0

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety