

P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO Phone: 705-652-2000 FAX: 705-652-6365

PVNC Catholic DSB (Reg243 - St Peter's SS - Day Care)

Attn : Mwenu Amukun

1355 Lansdowne Street West Peterborough, ON K9J 7M3, Canada

Works #: 500098645 Project : PO#126993

02-November-2023

Date Rec.: 28 October 2023 LR Report: CA18948-OCT23

Copy: #1

Phone: Office: 705-748-4861 Ext. 1286 Cell: 416-770-5521 Fax:

CERTIFICATE OF ANALYSIS **Final Report**

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date			02-Nov-23
2: Analysis Start Time			06:50
3: Analysis Completed Date			02-Nov-23
4: Analysis Completed Time			10:17
5: MAC			10
6: MDL			0.01
7: TAP Standing - Daycare Fixture	19-Oct-23 22:00	12.0	0.09
8: TAP Flushed - Daycare Fixture	19-Oct-23 22:35	12.0	0.10

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury Project Specialist, Environment, Health & Safety

0003520374

Page 1 of 1 Results relate only to the sample tested. Data reported represents the sample submitted to SGS. Reproduction of this analytical report in full or in part is prohibited without prior written approval. Please refer to SGS General Conditions of Services located at https://www.sgs.ca/en/terms-and-conditions (Printed copies are available upon request.) Test method information available upon request. "Temperature Upon Receipt" is representative of the whole shipment and may not reflect the temperature of individual samples. SGS Canada Inc. Environment-Health & Safety statement of conformity decision rule does not consider uncertainty when analytical results are compared to a specified standard or